



OVERALL SITE PLAN AND FIBER NETWORK DIAGRAM  
SCALE: 1/32" = 1'-0"

GENERAL NOTES

1. REFER TO FIRELITE INTELLIGENT CONTROL PANEL AND TROUBLESHOOTING GUIDELINES.
2. THE OPERABLE PART OF FIRE ALARM PULL STATIONS SHALL BE MOUNTED BETWEEN 42" AND 54" ABOVE THE WALKING SURFACE.
3. WALL-MOUNTED HORN/STROBES AND STROBES SHOULD BE INSTALLED SO THAT THE ENTIRE LENS IS BETWEEN 80" AND 96" ABOVE WALKING SURFACE AND SYNCHRONIZED.
4. WALL-MOUNTED HORNS SHOULD BE INSTALLED SO THAT THE TOP OF THE APPLIANCE IS NOT LESS THAN 96" ABOVE THE FINISHED FLOOR.
5. SMOKE DETECTORS, WHERE APPLICABLE, SHOULD NOT BE LOCATED IN A DIRECT AIR FLOW NOR CLOSER THAN 3 FEET TO AN AIR SUPPLY DEFUSER OR RETURN AIR OPENING.
6. SEE DRAWING No. FA-1 GENERAL NOTES, SYMBOL LEGEND, CABLE TAG IDENTIFICATION AND INDEX OF DRAWINGS.
7. SEE DRAWING No. FA-X FOR DEVICE WIRING DIAGRAMS AND REMOTE POWER SUPPLY (FPS) LAYOUT AND WIRING DETAILS.

REVISIONS

REVISION	DESCRIPTION	BY:	CHK:	DATE
0	ORIGINAL ISSUE	PLJ	JB	2/22/15

PROJECT LOCATION:

VAS APARTMENTS, LLC  
VILLAGE CLUB AT SANDHILL APARTMENTS  
COLUMBIA, SOUTH CAROLINA 29229

DRAWN

ISSUE DATE: 2/22/2015  
DESIGNED BY: *Shad J. Stephens*  
PROJECT No.: SBT-007  
APPROVED BY: *Shad J. Stephens*  
SCALE: 1/32" = 1'-0"

DRAWING TITLE:

FIRE ALARM AND DETECTION SYSTEM  
OVERALL SITE PLAN  
AND FIBER NETWORK DIAGRAM

DRAMA

STEEL-BAR TECHNOLOGY  
2839 GRAY FOX ROAD  
MONROE, NORTH CAROLINA 28079  
(704) 680-7595

DRAWING NO.:

FA-2

SIZE

ARCH D

REVISION

0