



5 120VAC, 60Hz FROM DEDICATED CIRCUIT WITH BREAKER LOCK  
 5 FIBER OPTIC TO FACP-2 (NODE 2), SEE DRAWING No. FA-2 FOR NETWORK DIAGRAM  
 5 FIBER OPTIC FROM FACP-5 (NODE 5), SEE DRAWING No. FA-2 FOR NETWORK DIAGRAM

BUILDING 1

FIRST FLOOR

GENERAL NOTES

1. REFER TO FIRELITE INTELLIGENT CONTROL PANEL SLC WIRING MANUAL FOR DEVICE WIRING EXAMPLES AND TROUBLESHOOTING GUIDELINES.
2. SEE DRAWING No. FA-1 GENERAL NOTES, SYMBOL LEGEND AND INDEX OF DRAWINGS.
3. SEE DRAWING No. FA-23 FOR INPUT/OUTPUT MATRIX.
4. SEE DRAWING No. FA-3, FA-4, FA-5 AND FA-6 FOR DEVICE LAYOUT AND WIRING.

REVISIONS

REVISION	DESCRIPTION	BY:	CHK:	DATE	PROJECT LOCATION	DRAWING TITLE	DRAWING NO.	SCALE	REVISION
0	ORIGINAL ISSUE			3/20/15	VAS APARTMENTS, LLC VILLAGE CLUB AT SANDHILL APARTMENTS COLUMBIA, SOUTH CAROLINA 29229	FIRE ALARM AND DETECTION SYSTEM AND RISER DIAGRAM BUILDING 1, 1ST - 3RD FLOORS	FA-22		0

DESIGNED: *Shad J. Sifuentes*  
 APPROVED: *Shad Sifuentes*  
 DRAWN: *Shad J. Sifuentes*  
 PROJECT No. SP1-007  
 SCALE: NONE  
 ISSUE DATE: 3/20/2015  
 DRAWING NO. FA-22  
 ARCH: D  
 REVISION: 0  
 STEEL-BAR TECHNOLOGY  
 2839 GRAY FOX ROAD  
 MONROE, NORTH CAROLINA 28079  
 (704) 680-7595